

NEC TABLE 250.122: EQUIPMENT GROUNDING CONDUCTORS

| RATING/SETTING OF OCPD (AMPS) | EGC SIZE (CU) | EGC SIZE (AL/CU-CLAD AL) |
|--------------------------------------|----------------------|---------------------------------|
| 15 | 14 | 12 |
| 20 | 12 | 10 |
| 60 | 10 | 8 |
| 100 | 8 | 6 |
| 200 | 6 | 4 |
| 300 | 4 | 2 |
| 400 | 3 | 1 |
| 500 | 2 | 1/0 |
| 600 | 1 | 2/0 |
| 800 | 1/0 | 3/0 |

| RATING/SETTING OF OCPD (AMPS) | EGC SIZE (CU) | EGC SIZE (AL/CU-CLAD AL) |
|--------------------------------------|----------------------|---------------------------------|
| 1000 | 2/0 | 4/0 |
| 1200 | 3/0 | 250 kcmil |
| 1600 | 4/0 | 350 kcmil |
| 2000 | 250 kcmil | 400 kcmil |
| 2500 | 350 kcmil | 600 kcmil |
| 3000 | 400 kcmil | 600 kcmil |
| 4000 | 500 kcmil | 750 kcmil |
| 5000 | 700 kcmil | 1200 kcmil |
| 6000 | 800 kcmil | 1200 kcmil |

ZING²

TECHNICAL REFERENCE DATA

PRO GRADE DOCUMENTATION



ONLINE ELECTRICAL TOOLS

<https://zing2.app>

VISIT ZING2.APP FOR FULL TABLE