

300.5: MINIMUM COVER REQUIREMENTS (FULL)

LOCATION OF WIRING METHOD	COL 1: DIRECT BURIAL CABLES (IN)	COL 2: RMC / IMC (IN)	COL 3: NONMETALLIC RACE
All locations not specified below	24	6	18
In trench below 2 in. concrete or equivalent	18	6	12
Under a building (in raceway only)	0	0	0
Under min. 4 in. thick concrete exterior slab (no vehicular traffic)	18	4	4
Under streets, highways, roads, alleys, driveways, and parking lots	24	24	24
One- and two-family dwelling driveways and outdoor parking areas	18	18	18
In or under airport runways	18	18	18

ZING²

TECHNICAL REFERENCE DATA

PRO GRADE DOCUMENTATION



ONLINE ELECTRICAL TOOLS