NEC 2023 COMPLIANT

NEC TABLE 300.5: MINIMUM BURIAL DEPTHS

LOCATION	DIRECT BURIAL (IN)	RIGID METAL / EMT (IN)	PVC/NON-METALLIC (IN)
General (Not under slabs)	24	6	18
Under residential driveways	18	18	18
Under individual residential garage	18	18	18
Under public streets/alleys	24	24	24
In airport / heavy traffic areas	24	24	24